

BRL-K14006

2018-12-01

Evaluation Guideline

for the Kiwa product certificate for
Inner hoses to be used for flexible connecting hoses



**Trust
Quality
Progress**



Preface

This evaluation guideline has been accepted by the Kiwa Board of Experts Watercycle (CWK), in which all relevant parties in the field of Inner hoses to be used for flexible connecting hoses are represented. The Board of Experts also supervises the certification activities and where necessary requires the evaluation guideline to be revised. All references to Board of Experts in this evaluation guideline pertain to the above mentioned Board of Experts.

This evaluation guideline will be used by Kiwa in conjunction with the Kiwa Regulations for Certification.

>

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

© 2018 Kiwa N.V.

All rights reserved. No part of this report may be reproduced, stored in a database or retrieval system, or published, in any form or in any way, electronically, mechanically, by print, photoprint, microfilm or any other means without prior written permission from the publisher.

The use of this evaluation guideline by third parties, for any purpose whatsoever, is only allowed after a written agreement is made with Kiwa to this end.

Binding declaration

This evaluation guideline has been declared binding by Kiwa on 1 December 2018



Contents

1	Introduction	4
1.1	General	4
1.2	Field of application / scope	4
1.3	Acceptance of test reports provided by the supplier	4
1.4	Quality declaration	4
2	Terms and definitions	5
2.1	Definitions	5
3	Procedure for granting a product certificate	7
3.1	Pre-certification tests	7
3.2	Granting the product certificate	7
4	Requirements	8
4.1	General	8
4.2	Suitability for contact with drinking water	8
4.3	Product requirements	8
5	Test methods	9
5.1	Determination of air tightness	9
5.2	Determination of resistance to low temperature	9
5.3	Determination of resistance to high temperature	9
6	Marking	10
6.1	General	10
6.2	Certification mark	10
7	Requirements in respect of the quality system	11
7.1	Manager of the quality system	11
7.2	Internal quality control/quality plan	11
7.3	Control of test and measuring equipment	11
7.4	Procedures and working instructions	11
7.5	Other requirements	11
8	Summary of tests and inspections	12
8.1	Test matrix	12
8.2	Inspection of the quality system of the supplier	12
9	Agreements on the implementation of certification	13



9.1	General	13
9.2	Certification staff	13
9.3	Report pre-certification tests	15
9.4	Decision for granting the certificate	15
9.5	Layout of quality declaration	15
9.6	Nature and frequency of third party audits	15
9.7	Report to the Board of Experts	16
9.8	Non conformities	16
9.9	Interpretation of requirements	16
10	Titles of standards	17
10.1	Public law rules	17
10.2	Standards / normative documents	17
I	Model certificate (informative)	18
II	Model IQC-scheme (informative)	19

>



1 Introduction

1.1 General

This evaluation guideline includes all relevant requirements which are adhered to by Kiwa as the basis for the issue and maintenance of a certificate for Inner hoses to be used for flexible connecting hoses.

This BRL replaces BRL-K14006/02, dated 2012-02-01.

For the performance of its certification work, Kiwa is bound to the requirements as included in NEN-EN-ISO/IEC 17065 "Conformity assessment - Requirements for bodies certifying products, processes and services".

1.2 Field of application / scope

The products are intended to be used as inner hoses of flexible connecting hoses as meant in the Kiwa evaluation guideline BRL-K622 "Flexible connecting hoses". These flexible connecting hoses are designed for using in drinkingwater installations with a maximum water pressure of 1000 kPa and a maximum water temperature of 90 °C.

1.3 Acceptance of test reports provided by the supplier

If the supplier provides reports from test institutions or laboratories to prove that the products meet the requirements of this evaluation guideline, the supplier shall prove that these reports have been drawn up by an institution that complies with the applicable accreditation standards, namely:

- NEN-EN-ISO/IEC 17020 for inspection bodies;
- NEN-EN-ISO/IEC 17021 for certification bodies certifying systems;
- NEN-EN-ISO/IEC 17024 for certification bodies certifying persons;
- NEN-EN-ISO/IEC 17025 for laboratories;
- NEN-EN-ISO/IEC 17065 for certification bodies certifying products.

Remark:

This requirement is considered to be fulfilled when a certificate of accreditation can be shown, issued either by the Board of Accreditation (RvA) or by one of the institutions with which an agreement of mutual acceptance has been concluded by the RvA. The accreditation shall refer to the examinations as required in this evaluation guideline. When no certificate of accreditation can be shown, Kiwa shall verify whether the accreditation standard is fulfilled.

1.4 Quality declaration

The quality declaration to be issued by Kiwa is described as a Kiwa product certificate. A model of the certificate to be issued on the basis of this evaluation guideline has been included for information as Annex.



2 Terms and definitions

2.1 Definitions

In this evaluation guideline, the following terms and definitions apply:

- **Board of Experts:** the Board of Experts Watercycle (CWK);
- **Certification mark:** a protected trademark of which the authorization of the use is granted by Kiwa, to the supplier whose products can be considered to comply on delivery with the applicable requirements and possibly with quality information on the application of the product is added by a specially designed label which is based on the result, as stated in the report issued by Kiwa on the inspection of the prototype;
- **Drinking water:** water intended or partly intended for drinking, cooking or food preparation or other domestic purposes, but does not include hot water, and is made available by pipeline to consumers or other customers.
- **Drinking water installation:** an installation direct or in-direct connected to the public drinking water distribution network of a drinking water company (source Dutch drinking water act);
- **Evaluation Guideline (BRL):** the agreements made within the Board of Experts on the subject of certification;
- **House hold water:** non-potable water that may only be used within premises for flushing toilets (source Dutch drinking water act);
- **Installation:** configuration consisting the pipe work, fittings and appliances;
- **Inspection tests:** tests carried out after the certificate has been granted in order to ascertain whether the certified products continue to meet the requirements recorded in the evaluation guideline.
- **IQC scheme (IQCS):** a description of the quality inspections carried out by the supplier as part of his quality system.
- **Pre-certification tests:** tests in order to ascertain that all the requirements recorded in the evaluation guideline are met.
- **Private Label Certificate:** A certificate that only pertains to products that are also included in the certificate of a supplier that has been certified by Kiwa, the only difference being that the products and product information of the private label holder bear a brand name that belongs to the private label holder.
- **Product certificate:** a document in which Kiwa declares that a product may, on delivery, be deemed to comply with the product specification recorded in the product certificate.
- **Product requirements:** requirements made specific by means of measures or figures, focussing on (identifiable) characteristics of products and containing a limiting value to be achieved, which can be calculated or measured in an unequivocal manner.



- **Supplier:** the party that is responsible for ensuring that the products meet and continue to meet the requirements on which the certification is based.
- **Tap water:** water intended for drinking, cooking or food preparation or other domestic purposes.
Note: Tap water includes drinking water, hot tap water and house hold water

>



3 Procedure for granting a product certificate

3.1 Pre-certification tests

The pre-certification tests to be performed are based on the (product) requirements as contained in this evaluation guideline, including the test methods, and comprises the following:

- type testing to determine whether the products comply with the product and/or functional requirements;
- production process assessment;
- assessment of the quality system and the IQC-scheme;
- assessment on the presence and functioning of the remaining procedures.

3.2 Granting the product certificate

After finishing the pre-certification tests, the results are presented to the Decision maker (see 9.2) deciding on granting the certificate. This person evaluates the results and decides whether the certificate can be granted or if additional data and/or tests are necessary.

>



4 Requirements

4.1 General

This chapter contains the requirements the Inner hoses to be used for flexible connecting hoses have to fulfil. These requirements will make part of the technical specification of the products, as included in the certificate.

4.2 Suitability for contact with drinking water

Products and materials which (may) come into contact with drinking water or warm tap water, shall not release substances in quantities which can be harmful to the health of the consumer, or negatively affect the quality of the drinking water. Therefore, the products or materials shall meet toxicological, microbiological and organoleptic requirements as laid down in the currently applicable "Ministerial Regulation materials and chemicals drinking water and warm tap water supply", (published in the Government Gazette). Consequently, the procedure for obtaining a recognised quality declaration, as specified in the currently effective Regulation, has to be concluded with positive results.

Products and materials with a quality declaration¹, e.g. issued by a foreign certification institute, are allowed to be used in the Netherlands, provided that the Minister has declared this quality declaration equivalent to the quality declaration as meant in the Regulation.

4.3 Product requirements

4.3.1 Nominal size

The hose inside diameter shall be in accordance with table 1.

Nominal size	effective internal diameter in mm
DN6	5,5 to 6,5
DN8	7,5 to 8,5
DN10	9 to 11
DN13	12 to 14
DN15	15 to 17

Table 1 – Nominal size of diameters

4.3.2 Air tightness

Without use of special equipment, the inner hoses shall be tight at air pressures up to 450 kPa according the conditions specified in 5.1.

4.3.3 Resistance to low temperature

The inner hose shall be resistant to a temperature of -25°C . After being tested according to 5.2, the inner hose shall not show any cracking visible with a 6x magnifying lens and shall comply with article 4.3.2.

4.3.4 Resistance to high temperature

The inner hose shall be resistant to a temperature of 90°C . After being tested according to 5.3, the inner hose shall not show any cracking visible with a 6x magnifying lens and shall comply with article 4.3.2.

¹ A quality declaration issued by an independent certification institute in another member state of the European Community or another state party to the agreement to the European Economic Area, is equivalent to a recognized quality declaration, to the extent that, to the judgment of the Minister of the first mentioned quality declaration, is fulfilled the at least equivalent requirements as meant in the Regulation materials and chemicals drinking water- and warm tap water supply.



5 Test methods

5.1 Determination of air tightness

5.1.1 Test piece

Per nominal diameter 3 pieces of hose with a length of 350 mm.

5.1.2 Procedure for determination of air tightness

- a. Place the hose into a device to accomplish the required pressure;
- b. Increase the pressure in the connecting hose from 0 kPa up to (450 ± 20) kPa within 30 seconds and preserve the pressure at this point;
- c. Determine whether the hose is leaking over a period of 300 seconds (for instance by optical inspection under water).

5.2 Determination of resistance to low temperature

5.2.1 General

The test of resistance to low temperatures shall be carried out in accordance with ISO 4672.

5.2.2 Test piece

Per nominal diameter 3 pieces of hose with a length of 350 mm.

5.2.3 Procedure

- a. Place the test pieces in a straight condition, for 10 ± 1 hours, in a refrigerating room with a temperature of $-25 \pm 2^\circ\text{C}$,
- b. Bend the test pieces, with the windings against each other, for 4 seconds over a drum with an external diameter of 10x the external diameter of the hose.
- c. Bring the test pieces to room temperature and examine them with a 6x magnifying lens on cracking.
- d. Test the test pieces on air tightness according to 5.1

5.3 Determination of resistance to high temperature

5.3.1 Test piece

Per nominal diameter 3 pieces of hose with a length of 350 mm.

5.3.2 Procedure

- a. Place the test pieces into a device to accomplish the required pressure.
- b. Fill the test pieces with water and de-aerate them.
- c. Increase the pressure in the pieces from 0 kPa up to (450 ± 20) kPa within 30 seconds and preserve this pressure.
- d. Store the test pieces in a furnace with a temperature of $90 \pm 3^\circ\text{C}$ for a period of 168 ± 2 hours.
- e. Bring the test pieces to room temperature and examine them with a 6x magnifying lens on cracking.
- f. Test the test pieces on air tightness according to 5.1.



6 Marking

6.1 General


The cartridge shall be provided with the following markings:

- manufacturer's name or mark,
- type coding of the hose,
- digits indicating the month and year of production (MM/YYYY).

The marking shall be legible and indelible.

6.2 Certification mark

After concluding a Kiwa certification agreement, the following certification mark shall be applied legible, indelible and visibly on the product:

The Kiwa Water Mark “**KIWA** ”

The packaging may be provided with the following mark:





7 Requirements in respect of the quality system

This chapter contains the requirements which have to be met by the supplier's quality system.

7.1 Manager of the quality system

Within the supplier's organizational structure, an employee who will be in charge of managing the supplier's quality system must have been appointed.

7.2 Internal quality control/quality plan

The supplier shall have an internal quality control scheme (IQC scheme) which is applied by him.

The following must be demonstrably recorded in this IQC scheme:

- which aspects are checked by the supplier;
- according to what methods such inspections are carried out;
- how often these inspections are carried out;
- in what way the inspection results are recorded and kept.

This IQC scheme should at least be an equivalent derivative of the model IQC scheme as shown in the Annex.

7.3 Control of test and measuring equipment

The supplier shall verify the availability of necessary test and measuring equipment for demonstrating product conformity with the requirements in this evaluation guideline.

When required the equipment shall be kept calibrated (e.g recalibration at interval).

The status of actual calibration of each equipment shall be demonstrated by traceability through an unique ID.

The supplier must keep records of the calibration results.

The supplier shall review the validity of measuring data when it is established at calibration that the equipment is not suitable anymore.

7.4 Procedures and working instructions

The supplier shall be able to submit the following:

- procedures for:
 - dealing with products showing deviations;
 - corrective actions to be taken if non-conformities are found;
 - dealing with complaints about products and/or services delivered;
- the working instructions and inspection forms used.

7.5 Other requirements

The supplier shall be able to submit the following:

- the organisation's organogram;
- qualification requirements of the personnel concerned.



8 Summary of tests and inspections

This chapter contains a summary of the following tests and inspections to be carried out in the event of certification:

- **pre-certification tests:** tests in order to ascertain that all the requirements recorded in the evaluation guideline are met;
- **inspection test: tests** carried out after the certificate has been granted in order to ascertain whether the certified products continue to meet the requirements recorded in the evaluation guideline;
- **inspection of the quality system of the supplier:** monitoring compliance of the IQC scheme and procedures.

8.1 Test matrix

Description of requirement	Article no. BRL- K14006	Tests within the scope of:	
		Pre- certification	Inspection by Kiwa after granting of certificate (number / year) <small>a,b)</small>
Materials			
Requirements to avoid deterioration of the quality of the drinking water	4.2	X	2
Marking			
General	6.1	X	2
Certification mark	6.2		2
Product Requirements			
Nominal size	4.3.1	X	2
Air tightness	4.3.2	X	2
Resistance to low temperature	4.3.3	X	1
Resistance to high temperature	4.3.4	X	1

a) In case the product or production process changes, it must be determined whether the performance requirements are still met.

- b) The frequency of inspection visits is defined in chapter 9.6 of this evaluation guideline. During the inspection test the inspector checks the products on basis of a selection from the above-mentioned product requirements. For this purpose, at least one tap is selected from each product family, with a maximum of 1/3 of all certified products. The inspections with regard to the products can be carried out by:
- the producer, in this own NEN-EN-ISO/IEC 17025 accredited laboratory
 - the producer, in the presence of the inspector
 - an NEN-EN-ISO/IEC 17025 accredited and recognized laboratory.

8.2 Inspection of the quality system of the supplier

The quality system of the supplier will be checked by Kiwa on the basis of the IQC scheme.

The inspection contains at least those aspects mentioned in the Kiwa Regulations for Certification.



9 Agreements on the implementation of certification

9.1 General

Beside the requirements included in these evaluation guidelines, the general rules for certification as included in the Kiwa Regulations for Product Certification also apply. These rules are in particular:

- the general rules for conducting the pre-certification tests, in particular:
 - the way suppliers are to be informed about how an application is being handled;
 - how the test are conducted;
 - the decision to be taken as a result of the pre-certification tests.
- the general rules for conducting inspections and the aspects to be audited,
- the measures to be taken by Kiwa in case of Non-Conformities,
- the measures taken by Kiwa in case of improper use of Certificates, Certification Marks, Pictograms and Logos,
- terms for termination of the certificate,
- the possibility to lodge an appeal against decisions of measures taken by Kiwa.

9.2 Certification staff

The staff involved in the certification may be sub-divided into:

- Certification assessor (**CAS**): in charge of carrying out the pre-certification tests and assessing the inspectors' reports;
- Site assessor (**SAS**): in charge of carrying out external inspections at the supplier's works;
- Decision maker (**DM**): in charge of taking decisions in connection with the pre-certification tests carried out, continuing the certification in connection with the inspections carried out and taking decisions on the need to take corrective actions.

9.2.1 Qualification requirements

The qualification requirements consist of:

- qualification requirements for personnel of a certification body which satisfies the requirements EN ISO / IEC 17065, performing certification activities
- qualification requirements for personnel of a certification body performing certification activities set by the Board of Experts for the subject matter of this evaluation guideline

Education and experience of the concerning certification personnel shall be recorded demonstrably.

Basic requirements	Evaluation criteria
Knowledge of company processes Requirements for conducting professional audits on products, processes, services, installations, design and management systems.	<i>Relevant experience: in the field</i> SAS, CAS : 1 year DM : 5 years inclusive 1 year with respect to certification Relevant technical knowledge and experience on the level of: SAS : High school CAS, DM : Bachelor



Basic requirements	Evaluation criteria
Competence for execution of site assessments. Adequate communication skills (e.g. reports, presentation skills and interviewing technique).	SAS: Kiwa Audit training or similar and 4 site assessments including 1 autonomic under review.
Execution of initial examination	CAS: 3 initial audits under review.
Conducting review	CAS: conducting 3 reviews

Technical competences	Evaluation Criteria
Education	General: Education in one of the following technical areas: <ul style="list-style-type: none"> • Civil Engineering; • Engineering.
Testing skills	General: <ul style="list-style-type: none"> • 1 week laboratory training (general and scheme specific) including measuring techniques and performing tests under supervision ; • Conducting tests (per scheme).
Experience - specific	CAS <ul style="list-style-type: none"> • 3 complete applications (excluding the initial assessment of the production site) under the direction of the CAS • 1 complete application self-reliant (to be evaluated by PM) • 3 initial assessments of the production site under the direction of the PM • 1 initial assessment of the production site self-reliant (witnessed by PM) SAS <ul style="list-style-type: none"> • 5 inspection visits together with a qualified SAS • 3 inspection visits conducted self-reliant (witnessed by DM)
Skills in performing witnessing	Qualified SAS and CAS Internal training witness testing

Legenda:

- Certification assessor (**CAS**)
- Decision maker (**DM**)
- Product manager (**PM**)
- Site assessor (**SAS**)

9.2.2 Qualification

The qualification of the Certification staff shall be demonstrated by means of assessing the education and experience to the above mentioned requirements. In case staff is to be qualified on the basis of deflecting criteria, written records shall be kept.

The authority to qualify staff rests with the:

- **PM:** qualification of **CAS** and **SAS**;
- management of the certification body: qualification of **DM**.



9.3 Report pre-certification tests

The certification body records the results of the pre-certification tests in a report.

This report shall comply with the following requirements:

- completeness: the report provides a verdict about all requirements included in the evaluation guideline;
- traceability: the findings on which the verdicts have been based shall be recorded and traceable;
- basis for decision: the **DM** shall be able to base his decision on the findings included in the report.

9.4 Decision for granting the certificate

The decision for granting the certificate shall be made by a qualified Decision maker which has not been involved in the pre-certification tests. The decision shall be recorded in a traceable manner.

9.5 Layout of quality declaration

The product certificate shall be in accordance with the model included in the Annex.

9.6 Nature and frequency of third party audits

The certification body shall carry out surveillance audits on site at the supplier at regular intervals to check whether the supplier complies with his obligations. The Board of Experts decides on the frequency of audits.

At the time this BRL entered into force, the frequency of audits amounts 2 audit(s) on site per year for suppliers with a quality management system in accordance with ISO 9001 for their production, which has been certified by an acknowledged body (in accordance with ISO/IEC 17021) and where the IQC scheme forms an integral part of the quality management system.

In case the supplier is not in possession of any product certificate (issued by Kiwa or any other accredited certification body), the frequency is increased to 3 visits for the duration of one year.

The audit program on site shall cover at least:

- the product requirements;
- the production process;
- the suppliers IQC scheme and the results obtained from inspections carried out by the supplier;
- the correct way of marking certified products;
- compliance with required procedures;
- handling complaints about products delivered.

For suppliers with a private label certificate the frequency of audits amounts to 1 audit per 2 years. These audits are conducted at the site of the private label certificate holder. The audits are conducted at the site of private label holder and focussed on the aspects inserted in the IQC scheme and the results of the control performed by the private label holder. The IQC scheme of the private label holder shall refer to at least:

- the correct way of marking certified products;
- compliance with required procedures for receiving and final inspection;
- the storage of products and goods;
- handling complaints.

The results of each audit shall be recorded by Kiwa in a traceable manner in a report.



9.7 Report to the Board of Experts

De certification body shall report annually about the performed certification activities. In this report the following aspects are included:

- mutations in number of issued certificates (granted/withdrawn);
- number of executed audits in relation to the required minimum;
- results of the inspections;
- required measures for established Non-Conformities;
- received complaints about certified products.

9.8 Non conformities

When the certification requirements are not met, measures are taken by Kiwa in accordance with the sanctions policy as written in the Kiwa Regulation for Certification.

The Sanctions Policy is available page on the Kiwa website.

9.9 Interpretation of requirements

The Board of Experts may record the interpretation of requirements of this evaluation guideline in one separate interpretation document.

>



10 Titles of standards

10.1 Public law rules

BJZ2011048144
29 juni 2011

Regeling van de Staatssecretaris van
Infrastructuur en Milieu¹

10.2 Standards / normative documents

Number	Title
NEN-EN ISO/IEC 17020	Conformity assessment - General criteria for the operation of various types of bodies performing inspection
NEN-EN ISO/IEC 17021	Conformity assessment - Requirements for bodies providing audit and certification of management systems
NEN-EN ISO/IEC 17024	Conformity assessment - General requirements for bodies operating certification of persons
NEN-EN ISO/IEC 17025	General requirements for the competence of testing and calibration laboratories
NEN-EN ISO/IEC 17065	Conformity assessment - Requirements for bodies certifying products, processes and services
ISO 4672	Rubber and plastics hoses - Sub-ambient temperature flexibility tests

>

¹ Valid from 1 July 2017



I Model certificate (informative)



Product certificate
KXXXXXX/0X



Issued

Replaces

Page 1 of 1

CERTIFICATE

Name product

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Name customer

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-xxxx "xxxxxxxxxxxxxxxxxxxxxxxx" dated [dd-mm-yyyy]

inclusive amendment sheet dated dd-mm-yyyy.

Luc Leroy
Kiwa

Publication of this certificate is allowed.
Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 908 44 00
Fax +31 88 908 44 20
info@kiwa.nl
www.kiwa.nl

Company
Name customer
Address customer

Phone number
Fax number
www.
Email

Certification process consists of initial and regular assessment of:

- quality system
- product

140410



II Model IQC-scheme (informative)

Inspection subjects	Inspection aspects	Inspection method	Inspection frequency	Inspection registration
Raw materials or materials supplied: - recipe sheets - incoming goods inspection raw materials				
Production process, production equipment, plant: - procedures - working instructions - equipment - release of product				
Finished-products				
Measuring and testing equipment - measuring equipment - calibration				
Logistics				

>